



10 November 2023

Addendum 1 for USM BID 24-16 Hillcrest Air Cooled Chiller



Deidre Edwards

Buyer, Procurement and Contract Services

USM BID 24-16 is being amended to adjust the specifications as follows:

- Item 1. Paragraph 2.03 DESIGN REQUIREMENTS, 2.05.C Chiller Schedule
Clarification to Nom. (Nominal) Tons: Actual cooling capacity shall be 120 tons
+/- 5 tons at design conditions.
- Item 2. Paragraph 2.04 Chiller Components, 2.04.C.2 Condenser
Replace 2.04.C.2 with following.
 - 2. Condenser coil shall be microchannel or finned tube design. Each
condenser coil shall be factory leak tested.
- Item 3. Paragraph 2.05 OPTIONS AND ACCESSORIES, 2.05.A Hot Gas Bypass
Delete paragraph 2.05.A (Hot gas bypass not required)
- Item 4. Paragraph 2.05 OPTIONS AND ACCESSORIES, 2.05.J
Delete paragraph 2.05.J Remote operator interface panel (Not required)