



**THIS IS NOT  
AN ORDER**

**REQUEST FOR BIDS/PROPOSALS COVERSHEET**  
**THE UNIVERSITY OF SOUTHERN MISSISSIPPI**

**Procurement and Contract Services**

**118 College Drive #5003, Hattiesburg, Mississippi 39406-0001**

**Date:** March 4, 2024

**Name:** \_\_\_\_\_

**RFP No. 24-28**

**Company:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City/State/Zip:** \_\_\_\_\_

THE UNIVERSITY OF SOUTHERN MISSISSIPPI is considering the purchase of the following item(s). We ask that you submit your bid and retain one copy for your files. Right is reserved to accept or reject any part of your bid. Your quotation will be given consideration if received in Bond Hall, Room 214 on or before:

2:00 p.m. CT

TERMS - Bidder should state terms of sale. Our terms are 2% ten days, net 45 days.

These terms will apply per Mississippi law.

AWARDING CONTRACT - Cash terms will not be used as a basis for awarding contracts; however, the University will accept cash discounts when earned.

April 2, 2024

**Buyer:** Deidre Edwards

NOTE: If you cannot quote on the exact material shown, please indicate any exception giving brand name and complete specifications of any alternate. If additional space is required, use a separate sheet or letter of transmittal.

ITEM	QUANTITY	DESCRIPTION	UNIT PRICE	TOTAL NET PRICE
		<b>RFP 24-28 Physical Plant and Residence Life Maintenance Building Generator</b>  <b>RFx # 3160006483</b>		
		PROPOSAL MUST BE RETURNED TO THE UNIVERSITY IN ACCORDANCE WITH THE SPECIFICATIONS. RFP NUMBER AND DATE OF BID OPENING MUST BE SHOWN ON THE OUTSIDE OF THE ENVELOPE IF USING THAT METHOD.		

We quote you as above - F.O.B. The University of Southern Mississippi.

Shipment can be made in \_\_\_\_\_ days from receipt of order. DATE \_\_\_\_\_

Return quotation to Procurement Services at above address.

**The University of Southern Mississippi**  
**Request for Proposals # 24-28**  
**Physical Plant and Residence Life Maintenance Building Generator**

## **1.0 Introduction**

The University of Southern Mississippi (USM) is seeking to procure an emergency generator that will support the USM Physical Plant and Residence Life Maintenance Building, in the event of a campus-wide power failure. Vendors: Generac Generator and Taylor Generator are USM approved suppliers. All other generator suppliers must meet or exceed these minimum specifications to be considered.

## **2.0 Generac Generator/ATS Specifications**

**Quantity 1 - Generac Industrial gaseous engine-driven generator, turbocharged/aftercooled 6-cylinder 14.2L engine, consisting of the following features and accessories:**

- **SG0300GG20142S18PPSYG**
- **Stationary Emergency-Standby rated**
- **300 kW Rating, wired for 120/208 VAC three phase, 60 Hz**
- **Permanent Magnet Excitation**
- **Natural Gas fuel system**
- **Level 1 Acoustic Enclosure, Steel**
  - **Industrial Grey Baked-On Powder Coat Finish**
- **UL2200**
- **Power Zone Digital Control Panel for Single or MPS Generators**
  - Meets NFPA 99 and 110 requirements
  - Temp Range -40 to 70 degrees C
  - Humidity 2 – 95% (Non-Condensing)
  - UL6200
  - C-ETL-US
  - CE
  - FCC
  - IEC801 (Radiated Emissions, Susceptibility, and Surge Immunity)
  - 7" Resistive Color Touchscreen
    - Built-in Webserver
    - IP65 (front)
    - Auto/Manual/Off key switch, Alarm Indication, Not in Auto Indication, audible alarm, emergency stop switch
  - Dual Core Digital Microprocessor
    - RS485, Ethernet and CANbus ports
  - Sensors: Oil Pressure, optional Oil Temp, Coolant Temp and Level, Fuel Level/Pressure (where applicable), Engine Speed, DC Battery Voltage, Run-time Hours, Generator Voltages, Amps, Frequency, Power, Power Factor

- Alarm Status: Low or High AC Voltage, Low or High Battery Voltage, Low or High Frequency, Pre-low or Low Oil Pressure, Pre-high or High Oil Temp (optional), Low Water Level and Temp, Pre-high or High Engine Temp, High, Low, and Critical-low Fuel Level/Pressure (where applicable), Overcrank, Over and Under Speed, Unit Not in Automatic
  - Programmable I/O
  - Built-in PLC for special applications
- Engine function monitoring and control:
  - Full range standby operation; programmable auto crank, Emergency Stop, Auto-Off- Manual switch
  - Isochronous Governor
    - 0.25% digital frequency regulation with: soft-start ramping - adjustable, gain - adjustable, overshoot limit - adjustable
  - 3 Phase RMS Voltage Sensing
    - +/-0.5% digital voltage regulation with: soft-start voltage ramping - adjustable, loss of sensing protection - adjustable, negative power limit - adjustable, Hi/Lo voltage limit - adjustable, V/F slope and gain - adjustable, fault protection
- Service reminders, trending, fault history (alarm log)
- I2T function for full generator protection
- Selectable low-speed exercise
- 2 and 3-wire start controls for any industrial grade transfer switch
- 225 AH, 1155 CCA Group 8D Batteries, with rack, installed
- 1 Hour factory load testing at reactive (0.8) power factor
- Battery Charger, 10 Amp, NFPA 110 compliant, installed
- Coolant Heater, 2000W, 240VAC
- 3 Owner's Manuals
- 120V GFCI and 240V Outlet
- Alternator Strip Heater
- Engine Run Relay
- Flex Fuel Line
- Oil Temp Sender
- MLCB, 100% rated thermal-magnetic
  - 600 Amp
- MLCB, 100% rated thermal-magnetic
  - 600 Amp
- Standard 2-Year Limited Warranty
- SG0300GG20142S18PPSYG
- 21 light remote annunciator
- Remote E-stop

#### **Quantity 2 - TRANSFER SWITCH - TX SERIES**

- **TX301NS0600G3CH**
- **600 Amp, 3 pole, 120/208 VAC three phase, 60 Hz, with 2-Wire Start Circuit**

- **Utility Voltage Sensing Controls:**
  - **Adjustable Drop-out and Pick-up**
  - **Adjustable Utility Interrupt Delay**
- Adjustable Logic Controls:
  - Minimum Standby Voltage
  - Minimum Standby Frequency
  - Engine Warmup
  - Return to Utility
  - Engine Cooldown
  - Transfer on Exercise
- 3 Owner's Manuals
- Double Set of Form C Aux Cont
- Specific Breaker
- Withstand and Close-On Rating - 100kA Specific Breaker
- Enclosure Heater
- IO Board - 4 Inputs, 4 Outputs
- UL Listed 1008 by ETL
- NEMA 3R Enclosure
- Service Entrance Rated
- Specific Breaker
- In Phase Only Transfer
- Standard two-year basic warranty
- TX301NS0600G3CH Controller and Circuit Breaker Covers, Padlockable, Black

### **3.0 Generator/ATS Work Specifications**

- Furnish and the installation of a 300KW Generator with (2) 600amp ATS switches
- 300KW generator to be located at SE corner of existing Physical Plant building (605)
- Install (1) of the 600a SER, NEMA 3R, ATS outside of Physical Plant building adjacent to electrical room near existing Pad Transformer. The ATS will provide power for Physical Plant(605) and Physical Plant motor pool(610).
- Install the 2<sup>nd</sup> 600a SER, NEMA 3R, ATS at the NE corner of the Furniture Shop (615) west of the existing Transformer. The ATS will provide power to the Furniture Shop(615) and Residence Life(629) buildings.
- Boring (2) 4" conduits beginning at generator site and ending at 2<sup>nd</sup> ATS location (east side of furniture shop transformer).
- Provide a pad for the generator and each of the ATS. The generator and the ATS's are to be anchored to the slab.
- Building connection will be done after normal business hours
- Job site offloading
- System startup/NFPA 110 load bank
- NETA, infrared scanning, extended piping, leak testing

### **4.0 TAYLOR Generator Specifications**

## **Quantity 1 – TAYLOR Model TG300: Engine Driven Generator Set**

Rated: 300 Kw on Natural Gas, EPA Stationary Standby, 120/208 Volt, 3 Phase, 60Hz

### **Unit Features**

- **PSI Engine**
  - Model – 14.6L NG or LPV
  - 8 Cylinder
  - Heavy Duty Air Cleaner w/Service Indicator
  - 50 C Ambient Radiator
  - Electronic Isochronous Governor with 0.5% Frequency Regulation
- **Stamford Alternator**
  - Model – S4L1D-E41-311
  - Brushless Rotating Field Generator with Class H Insulation
  - 0.5% AVR, 3 Phase Sensing, PMG
  - Tropical Coating
- **Circuit Breaker**
  - (2)600 Amp, P-Frame, Square D, 100% Rated, Electronic (LI), Main Line Circuit Breaker
- **TAYLOR DGC2020 Control Panel**

Taylor Power Systems DGC-2020 digital genset controller provides integrated engine-genset control, protection, and metering in a single package. Microprocessor based technology allows for exact measurement, setpoint adjustment, and timing functions. Front panel controls and indicators enable quick and simple DGC-2020 operation. A wide temperature-range liquid crystal display (LCD) with backlighting can be viewed under a wide range of ambient light and temperature conditions. Taylor Power Systems also supplies a manual key override bypass switch that allows you to start the generator manually in the event of control systems failure.
- **Heavy Duty Integral Vibration Isolators between Engine/Alternator Base**
- **3" NPT Inlet Connection**
- **Oil Drain Kit (Oil Drain Piped to Edge of Skid w/Valve)**
- **Coolant Drain Kit**
- **Lube Oil & Antifreeze (Initial Fill)**
- **Battery Rack & Cables**
- **Stamford Wide Skid Base**
- **Flex Fuel Line**
- **208V, 4000W Block Heater w/Valves**
- **Battery Charger: SENS MicroGenius 2 (6Amp/24 Volt)**
- **(2) 12V Lead Acid Battery, 1100CCA**
- **Sound Attenuated Weather Enclosure w/Internal Critical Silencer. 1" UL-94 Sound Attenuating Foam**

- Heavy Duty 14 Ga. Steel
- Peaked Roof
- Bolted Construction
- Lockable Doors
- Stainless Steel Hardware
- Powder Coat Finish

**Misc:**

- **One Hour Factory Load Bank Test**
- **Four Hour Onsite Load Bank Test**
- **Standard 2 Year Standby Limited Warranty**
- **(1) Electronic O&M Manual**
- **Certified to UL2200**
- **Startup Inspection Performed after Completion of Installation**

**ASCO Series 300 Automatic Transfer Switch(es):**

- **(2) Service Entrance Rated Open Transition, 600 Amp, 3 Pole, Solid Neutral, NEMA 3R, with Programmable Exerciser**

## **5.0 Point of Contact**

For questions, contact the Buyer listed on the RFP Coversheet at:

[bids@usm.edu](mailto:bids@usm.edu)

## **6.0 Site Visit**

Vendors interested in submitting a response are encouraged to participate in a site visit and walk-thru of the facilities prior to submission to ensure you are familiar with all requirements/constraints. One date and time has been scheduled for the site visit/walk-thru, therefore all vendors interested in this opportunity to participate in this walk-thru must attend at that time and date. No additional site visits/walk-thru will be conducted. The date and time for the site visit/walk-thru will be Tuesday, March 13, at 10:00 AM CST. All interested vendors should meet at the USM Physical Plant Building a few minutes prior to that time. Following the walk-through, a question and answer session will be held. All relevant questions and answers that potentially could affect all proposers will be distributed as an addendum to the BID to all vendors who have registered their intent to submit a few days after this date.

## **7.0 Submission Instructions to Bidders**

One (1) signed original, two (2) copies, and one (1) portable virus/malware free electronic version (USB jump drive) of the sealed bid response (if electronic copy is not included, USM reserves the right to request an electronic copy of the exact bid response prior to review of the bid), subject to the conditions made a part hereof, will be received by **2:00 PM CDT on Tuesday, April 2, 2024**, in the USM Procurement and Contract Services office, as indicated in the General Terms, Conditions, and Instructions to Bidders described herein. It is the responsibility of the respondent to ensure

that the proposal package arrives in the Procurement and Contract Services Office.

Each bid **must** be submitted in a sealed envelope bearing on the outside the name “RFP # 24-28 Physical Plant and Residence Life Maintenance Building Generator,” the name of the Vendor, and the opening date specified on the cover sheet.

Inside the envelope please include all specifications on the proposed generator, as well as the USM Pricing Sheet (**Attachment A**). Note – USM will only be purchasing a total of one (1) generator, but is requesting pricing, including installation, on both manufacturers.

Along with the bid response and other attachments, contractors will also need to write their Certificate of Responsibility (COR), or a statement that the bid enclosed does not exceed Fifty Thousand Dollars (\$ 50,000.00) on the outside of the response packet. If the COR/statement is not included on the outside, the response will be considered invalid and not opened. In addition, a copy of the COR, if the response is over \$50,000, must be included with the response documents.

For regular mail:

The University of Southern Mississippi  
Attn: Deidre Edwards, Buyer  
118 College Drive, Box 5003  
Hattiesburg, MS 39406  
RFP 24-28

For FedEx, UPS, or other express couriers:

The University of Southern Mississippi  
Attn: Deidre Edwards, Buyer  
2609 W. 4th Street  
Hattiesburg, MS 39401  
RFP 24-28

Hand-carried responses should be brought to:

The University of Southern Mississippi  
Attn: Deidre Edwards, Buyer  
214 Bond Hall  
Hattiesburg, MS 39406  
RFP 24-28

As an alternative to traditional sealed proposals in envelopes, the University of Southern Mississippi is capable of receiving electronic bid responses. While this option is available, it is not required and we ask that all potential respondents keep in mind that with any electronic system there could be delays or glitches with the submission process; therefore the University *highly encourages traditional sealed responses* which are either mailed or submitted in person.

Additionally, the University will not be responsible for issues with attempted submissions of bids using the electronic method.

Should a vendor choose to submit their response electronically, please follow the instructions below using the following website:

[https://www.ms.gov/dfa/contract\\_bid\\_search/Home/Sell](https://www.ms.gov/dfa/contract_bid_search/Home/Sell).

On this site you will find helpful links to procurement opportunities, as well as a link to supplier registration. If not already registered in this system, potential bidders will first need to click on 'Supplier Registration' and follow the steps outlined (a one-time process). Once registered, suppliers can return to the original website and click on 'Procurement Opportunities' where they can either search by keyword for the bid they desire to respond to or leave the search box blank and click 'Search' for a listing of all current bids and proposals for the various State of Mississippi offices.

**Please note that emailed bids will not be accepted.**

Any bid may be withdrawn prior to scheduled time for the opening of bids or authorized postponement thereof. Any bid received after the time and date specified will not be considered.

The University of Southern Mississippi reserves the right to accept or reject any or all proposals and to waive any formalities.

Vendors are responsible for examining all specifications, terms, conditions, and instructions of this request. Failure to do so will be at Vendor's risk.

In order to ensure all interested bidders receive any addenda that may be issued, proposers must email their intent to propose using the Intent to Bid link on the USM Bid Listing under RFP 23-20 prior to the deadline to submit:

<https://www.usm.edu/procurement-contract-services/current-bids-and-sole-source-notices.php>

## **8.0 USM General Terms, Conditions, and Instructions for Bids/Proposals**

- 1.) Failure to examine any drawings, specifications, and instructions will be at bidder's risk.
- 2.) Samples of items when called for must be furnished free of expense and if not destroyed in testing, will, upon request, be returned at the bidder's expense. Request for the return of samples must be made within ten (10) days following opening bids. Each individual sample must be labeled with bidder's name and manufacturer's brand name and number.
- 3.) As a public entity of the state, we use sealed bidding to ensure "fair and open competition" to ensure no one in the buying organization can influence the bidding process or steer the selection of a particular company by sharing competitive bid



information during the solicitation process. Generally, all bids must remain sealed until they are opened publicly at the time stated in the notice—advance disclosure of the terms of a bid may be cause for rejection of said bid. Bidders should never send advanced copies of a sealed bid via email or screenshots of electronic bids. Bidders must submit sealed bids to be opened at the time and place stated in the solicitation for the public opening of bids and must not be revealed to the buyer before that time. Bids must be signed and sealed with bidder's name and address on the outside of the envelope, and the date and time of the bid opening and the bid file number shown in the lower-left corner of the packages, envelopes, express mailing labels, boxes, etc.

- 4.) In order for your bid to be considered, it must be received and time stamped in our office by 2:00 P.M. of the bid opening date. It is the responsibility of the vendor to ensure their bid is received within the appointed time. If your bid package is not received in Bond Hall, Room 214, by 2:00 P.M. of the bid opening date, it will not be considered.

If you are delivering your bid, you need to hand carry the bid package to:

The University of Southern Mississippi  
Procurement Dept. (Bid)  
Bond Hall, Room 214  
Hattiesburg, Mississippi  
RFP # 24-28

If you are mailing your bid package via U.S. Postal Service, mail to:

The University of Southern Mississippi  
Procurement Dept. (Bid)  
118 College Drive #5003  
Hattiesburg, MS 39406-0001  
RFP # 24-28

If you are express mailing your bid package via Federal Express or UPS, or any other delivery service which requires the use of a physical address, deliver to:

The University of Southern Mississippi  
Procurement Dept. (Bid)  
2609 West 4<sup>th</sup> Street  
Hattiesburg, MS 39401  
RFP # 24-28

- 5.) Bids or proposals shall not be modified, corrected, altered, or amended after the specified closing time and the opening of such bids, unless otherwise noted in the request for bids or proposals.
- 6.) The University of Southern Mississippi reserves the right to reject any and all bids, to

waive any informality in bids, and unless otherwise specified by the bidders, to accept any items on the bid. If the bidder fails to state the time within which bids must be accepted, it is understood and agreed that The University of Southern Mississippi shall have 60 days to accept. The University of Southern Mississippi reserves the right to make an award to this bid on an all or none basis, or on a line by line basis, whichever serves the best interest of The University of Southern Mississippi.

- 7.) Contracts and purchases will be made or entered into with the lowest, responsible bidder meeting specifications.
- 8.) A written purchase order or contract award mailed or otherwise furnished to the successful bidder within the time of acceptance specified in the Invitation for Bid results in a binding contract without further action by either party. The contract shall not be assignable by the vendor in whole or in part without the written consent of The University of Southern Mississippi.
- 9.) Bid files may be examined during normal working hours by bid participants. Non-participants will be prohibited from obtaining any information relative to the bid until the official award has been made.
- 10.) If purchase orders or contracts are canceled because of the awarded vendor's failure to perform or request for price increase, that vendor shall be removed from our bidders' list for a period of 24 months.
- 11.) No addendum will be issued within a period of two (2) working days prior to the time and date set for the bid opening. Should it become necessary to issue an addendum within the two-day period prior to the bid opening, the bid date will be reset giving bidders ample time to answer the addendum.
- 12.) Alternate bids, unless specifically requested or allowed, will not be considered.
- 13.) Bid openings will be conducted open to the public. However, they will serve only to open the bids. No discussion will be entered into with any vendor as to the quality or provisions of the specifications, and no award will be made either stated or implied at the bid opening. After the close of the bid opening meeting, the bids will be considered to be in the evaluation process and will not be available for review by bidders. Proposal openings are not required to be open to the public; however, the resulting award is open for public inspection.
- 14.) Prices quoted shall be firm for the term of the contract or for the stated time of acceptance.
- 15.) The bidder understands that The University of Southern Mississippi is an equal opportunity employer and, therefore, maintains a policy which prohibits unlawful discrimination based on race, color, creed, sex, age, national origin, physical handicap,

disability, or any other such discrimination; and the bidder, by signing this bid, agrees during the term of agreement that the bidder will strictly adhere to this policy in its employment practices and provision of products or services.

- 16.) Bidders must upon request of The University of Southern Mississippi furnish satisfactory evidence of their ability to furnish products or services in accordance with the terms and conditions of these specifications. The University of Southern Mississippi reserves the right to make the final determination as to the bidder's ability.
- 17.) Questions or problems arising from bid procedures should be directed to the Buyer listed on the solicitation at:

The University of Southern Mississippi  
118 College Drive #5003  
Hattiesburg, MS 39406-0001  
Phone: (601) 266-4131

- 18.) All items must equal or exceed the specifications listed. The absence of detail specifications or the omission of detail description shall be recognized as meaning that only the best commercial practices are to prevail and that only first quality materials and workmanship are to be used.
- 19.) It is the intent of the specifications to obtain a product that will adequately meet the needs of the user while promoting the greatest extent of competition that is practicable. It is the responsibility of the prospective bidder to review the entire Invitation to Bid packet and to notify The University of Southern Mississippi if the Specifications, Instructions, General, or Special Conditions are formulated in a manner which would unnecessarily restrict competition.
- 20.) It shall be incumbent upon the bidders to understand the specifications. Any requests for clarifications shall be in writing and shall be submitted to our Procurement Services office at least five (5) days prior to the time and date set for the bid opening, unless otherwise noted in the bid or proposal specifications.
- 21.) The minimum specifications are used to set a standard and in no case are used with the intention to discriminate against any manufacturer. Bidders should note the name and the manufacturer and model number of the product they propose to furnish and submit descriptive literature.
- 22.) Trade names, brand names, and/or manufacturer's information used in these specifications are for the purpose of establishing quality, unless otherwise noted. Bids on products of other qualified manufacturers are acceptable, provided they are demonstrated as equal to those specified in construction, design and suitability. Each bidder shall submit with his bid a complete brochure with pictures on each item and shall point out specifically any deviations from the specified items. Failure to do so may

disqualify any bid. Please bid as specified or an approved equal.

- 23.) A copy of the manufacturer's standard guarantee/warranty shall accompany and become a part of this bid.
- 24.) There are no federal or state laws that prohibit bidders from submitting a bid lower than a price or bid given to the U.S. Government. Bidders may bid lower than U.S. Government contract price without any liability as The University of Southern Mississippi is exempt from the provisions of the Robinson-Patman Act and other related laws. In addition, the U.S. Government has no provisions in any of its purchasing arrangements with bidders whereby a lower price to The University of Southern Mississippi must automatically be given to the U.S. Government.
- 25.) All invoices, unless noted otherwise, are to be billed to:
- The University of Southern Mississippi  
Accounts Payable  
118 College Drive #5104  
Hattiesburg, MS 39406-0001
- 26.) All equipment bid shall be of current production and of the latest design and construction.
- 27.) Where all, or part(s), of the bid is requested on a unit price basis, both the unit prices and the extension of the unit prices constitute a basis of determining the lowest responsible and responsive bidder. In cases of error in the extension of price, the unit price will govern.
- 28.) All bidders/respondents are on notice that USM is a public agency of the State of Mississippi and is subject to the Mississippi Public Records Act, Miss. Code Ann. § 25-6-1, *et seq.* If a public records request is made for any information provided to the USM pursuant to this solicitation, USM shall promptly notify the Disclosing Party of such request. The Disclosing Party shall promptly institute appropriate legal proceedings to protect its information. No party to this agreement shall be liable to the other party for disclosures of information required by court order or required by law. For clarity, documents are not considered public record unless and until an award is made from such solicitation.
- 29.) Should the University of Southern Mississippi close due to inclement weather conditions, or any other unforeseen events on the bid opening date, sealed bids will open the following business day at the same time and location.
- 30.) As an alternative to traditional sealed bids in envelopes, the University of Southern Mississippi is capable of receiving electronic bid responses. While this option is available, it is not required and we ask that all potential respondents keep in mind that with any electronic system there could be delays or glitches with the submission process; therefore

the University highly encourages traditional sealed bids which are either mailed or submitted in person. Should a vendor choose to submit their response electronically, please follow the instructions below using the following website:  
[https://www.ms.gov/dfa/contract\\_bid\\_search/Home/Sell](https://www.ms.gov/dfa/contract_bid_search/Home/Sell). On this site you will find helpful links to procurement opportunities, as well as a link to supplier registration. If not already registered in this system, potential bidders will first need to click on 'Supplier Registration' and follow the steps outlined (a one-time process). Once registered, they can return to the original website and click on 'Procurement Opportunities' where they can either search by keyword for the bid they desire to respond to or leave the search box blank and click 'Search' for a listing of all current bids and proposals for the various State of Mississippi offices. Instructions on how to respond to an RFx in M.A.G.I.C. may be located at the following link:

<http://uperform.magic.ms.gov/gm/folder-1.11.9125?mode=EU&primaryCSH=RFx%2Cresponses>

NOTE: If you experience any problems with submitting your response through M.A.G.I.C. Please email the M.A.G.I.C. IT Helpdesk at [mash@dfa.ms.gov](mailto:mash@dfa.ms.gov).

**\*\*PLEASE NOTE: EMAILED BIDS WILL NOT BE ACCEPTED, AND IT MAY CAUSE YOUR BID TO BE REJECTED FOR EARLY DISCLOSURE. \*\***

With regard to construction bids, there is one additional step required during the bid submission process. Along with the bid response and other attachments, contractors will also need to attach their Certificate of Responsibility (COR), or a statement that the bid enclosed does not exceed Fifty Thousand Dollars (\$ 50,000.00). If their COR or such statement is not attached, the bid will be invalid and not considered.

**AA/EOE/ADA**

**The University of Southern Mississippi  
Request for Proposals (RFP) # 24-28  
Physical Plant and Residence Life Maintenance Building Generator**

**Attachment A – Pricing Sheet**

Manufacturer	PRICE (includes installation)
Generac	
Taylor	

**NOTE:** USM will only be purchasing a total of one (1) generator, but would like pricing, including installation, for both manufacturers.