

ADDENDUM NUMBER 1 to Specifications for RFP Bid #25-40

FROM: Corbett Legge & Associates, PLLC
431 West Main Street, Tupelo, MS 38804
PHONE: 662-844-7114
Cell: 662-401-1848

FOR ANSWERS TO QUESTIONS CONTACT:
Joseph Legge, PE jlegge@corbettlegge.com

PROJECT: OYSTER HATCHERY AND RESEARCH FACILITY
ON GCRL'S CEDAR POINT CAMPUS
UNIVERSITY OF SOUTHERN MISSISSIPPI
OCEAN SPRINGS, MISSISSIPPI

PROJECT #: **RFP Bid #25-40 Generator, Fuel System, and Automatic Transfer Switch**

ADDENDUM DATE: March 20, 2025

PLEASE BIND THIS ADDENDUM WITH YOUR SPECIFICATIONS

ELECTRICAL

ITEM NUMBER E1

REFERENCE: SPECIFICATION SECTION 263213 - "PACKAGED ENGINE GENERATOR & FUEL FILTERING SYSTEM (USM PURCHASED)"

ACTION: CHANGED 263213-2.2(C)1 TO READ AS FOLLOWS:

1. Power Output Rating: 800kW / 1,000kVA / 3,600skVA, 480Y/277V-3ph, 4-wire (0.8pf)

ACTION: CHANGED 263213-2.8(A) & (B) OUTDOOR GENERATOR-SET ENCLOSURE AS FOLLOWS:

1. The generator housing is to be ALUMINUM in lieu of steel listed. This is mentioned in (A) and (B) of the referenced section.

ITEM NUMBER E2

REFERENCE: SPECIFICATION SECTION 263600 - "TRANSFER SWITCHES (USM PURCHASED)"

ACTION: ADDED 263600-2.1(A)(4) TO READ AS FOLLOWS:

4. SERVICE ENTRANCE RATED (SER) AUTOMATIC TRANSFER SWITCH TO BE 1,200 AMPS (4-POLE)

END OF ADDENDUM